	Product Specifications	FZ01-360B1		1/4
	Flow Sensor	Model	Model ND□□-□ATAA□-l	
Reliability				
Creativity Service				

1-1. Specifications (ND05 / ND10)

· ·	ND037 ND 10					_		
Model	ND05-N ATAAC-RC	ND05-P ATAAC-RC	ND05-T ATAAA-RC	ND10-N ATAAA-RC	ND10)-P ATAAC-RC	ND10-T ATAAA-RC	
Nominal diameter		5mm			10m			
Accuracy guaranteed flow-rate range		0.3 to 3.0 L/mi	n	1.5 to 20 L/min 1.0 to 10 L/m			1.0 to 10 L/min	
Accuracy			±2%RS (At th	e standard instal	lation position)			
Fluid to be measured	For water and hot water	For water and c Note) Please sele by checking who parts main mate resistance again be measured.	ct suitable model ether the wetted erials have	For water and chemical fluids Note) Please select suitable model by che whether the wetted parts main materials resistance against your liquid to be meas		del by checking materials have		
Fluid viscosity range	9		0.5 to 1.5	mPa∙s(Equivaler	nt to water)			
Fluid temperature range	0 to +70°C	0 to +	-60°C	0 to +70°C		0 to +60°C		
Working ambient temperature/ humidity range			-10 to +70°C35 t	o 85%RH (No de	ew condensation))		
Maximum working pressure			1MPa (at th	ne fluid temperatu	ıre of 20°C)			
Pressure drop (at the accuracy guaranteed maximum flow-rate)	1	12 kPa or less	5	20 kPa or less 15 kPa or less				
Output signal		Maxi		NPN Open collector pulse m load24VDC6mA , Duty ratio3:7 <on:off<7:3< td=""></on:off<7:3<>				
Signal cable			ire length: Appro d: Power +/Black	•				
Pulse constant		2.5 mL/P			7.69 m	nL/P		
Maximum frequence (at the accuracy guaranteed maximum flow-rate)		20Hz		Approximately 44Hz Approximately 22Hz			Approximately 22Hz	
Minimum pulse ON time		15msec		Approximately 6.9msec Approximate 13.8msec			Approximately 13.8msec	
Standard installation	n		Position so the	that the brand mark (AC mark)				
position*1			on the name pl	plate faces up against the ground				
Flow direction			Arrow direc	tion indicated on	the product			
Pipe connection				R 1/2				
Protection grade			indoor speci	fications (Equival	ent to IP X4)			
Power supply	Same volta	age level should b	ne applied to the	3 to 24 VDC e sensor power (red-black) and pulse output (blue/white-black).				
Power consumption	ı			5mA or less				
Weight		Approximately 1	50g		Approximat	tely 120g		
Wain materials Wain waterials Wane wheel Pivot O-ring	Modified PPO	PP	ETFE	Modified PPO	PP)	ETFE	
Vane wheel	CF	F-POM	ETFE		CF-POM		ETFE	
Pivot	SUS304	PA	ETFE	SUS304	PA	1	ETFE	
.ii ≥ O-ring	NBR		CM .	NBR FKM				
Magnet		Sa-Co*2		Ba-l	i_		-Co ^{*2}	
Others		(CE Marking prod	uct , RoHS direct	ive corresponde	d		

.dlr.		Product Specifications		FZ01-360B1	2/4
	Reliability Creativity Service	Flow Sensor	Model	ND□□-□ATAAC]-RC


1-2. Specifications (ND20)

- 2. Opcom	Calions (ND20)	NID20 NI	ND20 D	ND20 D		
	Model	ND20-N ATAAA-RC	ND20-P ATAAA-RC	ND20-P ATAAC-RC		
N	lominal diameter	20mm				
occuracy g	uaranteed flow-rate range		3.0 to 60 L/min			
Accuracy		±2%RS	S (At the standard installation posi	tion)		
Flu	id to be measured	For water and hot water	For water and chemical fluids Note) Please select suitable model by checking whether the wetted parts main materials have resistance against your liquid to be measured.			
Flu	uid viscosity range	0.5	to 1.5 mPa·s(Equivalent to water)		
Fluid	I temperature range	0 to +70°C	0 to +6	0°C		
	Vorking ambient rature/humidity range	-10 to +7	0°C35 to 85%RH (No dew conden	sation)		
	num working pressure	ANDs (at the fluid town out two of 0000)				
	Pressure drop	TIVII	Pa (at the fluid temperature of 20°C	<u>')</u>		
(at the	accuracy guaranteed aximum flow-rate)		60 kPa or less			
		NPN Open collector pulse				
	Output signal	Maximum load24VDC6mA				
			Duty ratio3:7 <on:off<7:3< td=""><td></td></on:off<7:3<>			
	0: 1 11	Lead wire length: Approximately 600mm4-core AWG26 flat cable				
	Signal cable	(Red: Power +/Black GND/White: Output/Blue: Feedback)				
	Pulse constant	25 mL/P				
(at the	aximum frequency accuracy guaranteed aximum flow-rate)	40Hz				
	Minimum pulse ON time		7.5msec			
Standa	rd installation position*1	Position so that the brand mark (AC mark) on the name plate faces up against the ground				
	Flow direction	Arrow direction indicated on the product				
	Pipe connection	R 3/4				
	Protection grade	indoor specifications (Equivalent to IP X4)				
	Totocachi grado	3 to 24 VDC				
Power supply		Same voltage level should be applied to the sensor power (red-black) and pulse output (blue/white-black).				
Po	ower consumption	5mA or less				
	Weight		Approximately 360g			
ω*	Casing	Modified PPO	PP			
erial: oarts	Vane wheel	CF-POM				
nat ed p	Pivot	SUS304		PA		
Main materials of wetted parts ^{*3}	O-ring	NBR	FKN			
∑ ∮	Magnet	Ва	-Fe	Sa-Co ^{*2}		
	Others		ng product , RoHS directive corres			
		5 = 	5, 111, 1 2 120.00			

	Product Specifications		FZ01-360B1	3/4
Reliability Creativity Service	Flow Sensor	Model	ND□□-□ATAAE]-RC

*1:The standard installation position means the position that the brand mark on the nameplate (AC mark) faces upward against

Also, note that durability of the product is deteriorated in case of installation positions other than the standard installation position because amount of wearing is to be increased.



*2: This magnet is not in touch with liquid.

*3: Material symbols

Modified PPO Glass fiber reinforced NORYL (Polyphenylene oxide)

PP Polypropylene

Fluororesin (Ethylene-tetrafluoro ethylene) **ETFE**


CF-POM Carbon-fiber-filled Polyacetal or Polyoxymethylene

PA Polyamide SUS304 **Stainless** FKM Fluoro Rubber

NBR Nitrile Rubber (Acrylonitrile-Butadiene Rubber)

Samarium-Cobalt Sa-Co Barium-Ferrite Ba-Fe

2. Wiring technique



	Product Specifications	FZ01-360B1		4/4
Reliability	Flow Sensor	Model	ND□□-□ATAAE]-RC
Creativity Service				

3. Precautions for handling

- 3-1. Working environment, fluid to be measured
 - (1) Ensure that the wetted parts' materials have corrosion resistance against fluid to be measured.
 - (2) Keep the product away from a strong magnetic field or a source of electric noise.
 - (3)The product is not explosion-proof specification. Do not use the product in an explosive atmosphere such as flammable gas, etc.
 - (4)In case flow in the pipe has pulsation, the measurement accuracy is to be affected. When feeding the fluid with a constant rate pump, etc., which causes pulsation of flow, cancel the pulsation using an accumulator, etc.
 - (5) Avoid installation at a place exposed to direct sunlight and/or rain (Indoor specification).

3-2. Precautions for piping

- (1)No air shall be in the fluid to be measured. The measurement accuracy is to be affected.
 - Do not install the product at a place where air accumulation can easily occur (e.g. upstream side of a falling pipe. Also, before start measurement, remove air sufficiently.
- (2)For the installation position, install the product in the standard installation position (The brand mark on the nameplate faces upward against the ground).
- (3)Devices such as a flow-rate adjusting valve, etc., which disturb flow shall be installed in the downstream of the flowsensor.
- (4)Avoid installing the product where it is exposed to excessive pressure, such as water hummer, etc.
- (5)In case foreign substances, oil, etc., exist in the piping, install the flowsensor after cleaning inside of the pipe.
- (6)Make sure to align the flow direction of the fluid with the flow direction indicated by the arrow on the main body.
- (7)Provide straight pipe portion of 5D or more at the upstream and 3D or more at the downstream of the flowsensor.
- (8)Around the place of installation, provide enough space for maintenance.